



Product Service

# Attestation of Conformity

No. N8A 14 10 89558 002

**Holder of Certificate:** Vietnam Electric Cable Corporation (CADIVI)70-72 Nam Ky Khoi Nghia street, Nguyen Thai Binh ward, Dist 1  
70000 Ho Chi Minh City  
VIETNAM**Product:** PVC insulated, PVC sheathed flexible cords (Flexible cables(cords))**Model(s):** H05VVH2-F, H05VV-F

<b>Parameters:</b>	Rated voltage:	300/500V
	Number of conductors:	H05VVH2-F: 2 H05VV-F: 2-5
	Nominal cross-sectional area of conductor:	H05VVH2-F: 0.75-1.5mm <sup>2</sup> H05VV-F: 0.75-4mm <sup>2</sup>

**Tested according to:** EN 50525-2-11:2011  
EN 50525-1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 64100140051801**Date,** 2014-10-15
  
( Boris Ouyang )
**Valid until:** 2019-10-14

**CE** After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1