

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50472811

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
L.T.L.

Unser Zeichen *Our Reference*  
01-WSW-60388312 001

Ausstellungsdatum *Date of Issue*  
17.07.2020 (day/mo/yr)

**Genehmigungsinhaber *License Holder***  
VIETNAM ELECTRIC CABLE  
CORPORATION  
70-72 Nam Ky Khoi Nghia str.  
Nguyen Thai Binh ward,  
Dist. 1 Ho Chi Minh city 70000  
Vietnam

**Fertigungsstätte *Manufacturing Plant***  
CADIVI DONGNAI CO.,LTD.  
Line 1, Long Thanh Industrial  
Zone, Tam An, Long Thanh district,  
Dong Nai province  
Vietnam

## Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*  
EN 50618:2014

**Zertifiziertes Produkt (Geräteidentifikation)**  
*Certified Product (Product Identification)*

**Lizenzentgelte - Einheit**  
*License Fee - Unit*

Cables / Wires (Electric Cables for Photovoltaic Systems)

Type Designation	: H1Z2Z2-K 1X1,5...240mm <sup>2</sup> VIETNAM ELECTRIC CABLE CORPORATION	19
Rated Voltage	: DC 1,5kV AC 1,0/1,0kV	
Ambient Temperature	: -40°C to +90°C	
Max. Temperature at Conductor	: 120°C	

19

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 <http://www.tuv.com/safety>



Bo Liu